



Do you PAT test extra low voltage items such as laptops & mobile phone chargers?

It's important to remember that the Electricity at Work Regulations covers all electrical 'systems' & therefor includes equipment operating at all voltages. These items should be added to the asset register, a risk assessment must be carried out & the appropriate test regime implemented with results logged. In some cases it may just be a 'visual only' inspection as the amount of testing which can be carried out on this type of equipment may be minimal.

If you require more help, please contact us at <https://www.seaward.com/gb/enquiry/>.