What are the rules on record keeping for those undertaking the testing?

Although there is no legal requirement to keep records of inspection & testing, the HSE Memorandum of Guidance on the Electricity at Work Regulations 1989 advises that records of maintenance inculding tests should be kept throughout the working life of the appliance. Records provide evidence that the testing has been carried & most organisations will store their records electronically in PAT record software.

Click here to download a free 30 day trial of our PATGuard 3 PAT testing software.

If you require more help, please contact us at https://www.seaward.com/cms/enquiry/.

15-18 Bracken Hill, South West Industrial Estate, Peterlee, County Durham, SR8 2SW, United Kingdom
t: +44 (0) 191 586 3511 | f: +44 (0) 191 586 0227 | e: sales@seaward.com
seaward.com